





NO.	EXTERNAL OUTFALLS
001	DISCHARGE OF CONDENSER COOLING WATER FROM WHIF AT DIKE 3
009	SETTLING POND
013	TURBINE BUILDING SUMP & STORM WATER
014	TURBINE BUILDING SUMP & STORM WATER
016	INTAKE SCREEN WASH WATER
020	REVERSE OSMOSIS REJECT
021	REVERSE OSMOSIS DRAIN LINE
022	DRAINAGE AREA #2A (STORM WATER ONLY)
023	DRAINAGE AREA #2B (STORM WATER ONLY)
024	DRAINAGE AREA #3 (STORM WATER ONLY)
025	DRAINAGE AREA #18 (STORM WATER ONLY)
026	DRAINAGE AREA #25 (STORM WATER ONLY)
NO.	INTERNAL OUTFALLS
103	PROCESS WASTE CLARIFIER
104	OIL/WATER SEPARATOR, TURBINE BUILDING SUMP & STORM WATER
106	BEARING COOLING TOWER BLOWDOWN
107	BEARING COOLING SYSTEM DISCHARGE
108	SERVICE WATER OVERBOARD
109	HOT WELL DRAIN - UNIT 1
110	HOT WELL DRAIN - UNIT 2
111	MAIN WASTE TREATMENT PLANT
112	STEAM GENERATOR BLOWDOWN - UNIT 1
113	STEAM GENERATOR BLOWDOWN - UNIT 2
114	SERVICE WATER TIE-IN VAULT DRAIN
115	SERVICE WATER SYSTEM BLOWDOWN

NOTES:
 1. THIS DRAWING IS REQUIRED BY EPA FORM 3510-1, SECTION XI AND EPA FORM 3510-2F, SECTION III.